

# Yesler Terrace electrical distribution

## Reasons SHA selected overhead electrical distribution for Yesler Terrace

- topography and accessibility issues
- corridor constraints
- aesthetics and First Hill Streetcar
- scheduling and sequencing opportunities
- cost

# Requiring undergrounding now

Consequences of requiring undergrounding at this stage would include:

- **Additional project cost** for redesign of infrastructure
- **Delay** in:
  - Achieving approved Final Plat and Street Improvement plans
  - Construction of replacement housing
  - Sale of land for moderate-income housing and market-rate units



Example of aboveground equipment (switchpad with bollards) needed to support underground utility system